

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 3774-0923:0104

Page 1 of 1

CATEGORY: 3774 -- ELECTRIC LOCKS

LISTEE: SECURITRON MAGNALOCK550 Vista Blvd, Sparks, NV 89434
Contact: Erik Strauss (775) 355-5625 Fax (775) 355-5638
Email: eriks@securitron.com

DESIGN: Models EEB2 and EEB3N exit button. Units deactivate electric locks and are designed with integrated timer. Buttons are to be installed on the inside of a door and when pressed, will release the locking mechanism for 30 seconds. Refer to listee's data sheet for detailed product description and operational considerations.

RATING: 12 or 24 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances, NFPA 101 and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as electric locking system for access control. Intended for installation on non-fire rated doors. Authority having jurisdiction shall be consulted prior to installation.

NOTE: Models may be used in conjunction with a separately listed fire alarm control panel, however, the units must be connected via the panels dry relay contacts designated as "Auxiliary". Connection to the fire alarm control unit "trouble" or "alarm relay" contacts is **NOT** approved.

12-15-2002 IPI



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **July 01, 2010**

Listing Expires **June 30, 2011**

Authorized By: **FRANCIS MATEO**, Program Coordinator
Fire Engineering Division